



No. 1422197.2

(Please quote this number in all correspondence)

CLIENT:
Floorco Trading Ltd.
38 Galway St.
Onehunga, Auckland

Attn.: Henry Zhai

SAMPLE RECEIVED FROM:
Floorco

Date Received: 1.7.22

SAMPLE DESCRIPTION:
5 flooring planks:
a) SPC Flooring
b) Laminate Flooring (1)
c) Laminate Flooring (2)
d) Engineered Wood Flooring (1)
e) Engineered Wood Flooring (2)

Client Order No.:

Client Reference:

1 of 2

BS 8493:2008 + A1:2010 - LIGHT REFLECTANCE VALUE (LRV) OF A SURFACE

Date Tested: 8/7/2022
Instrumentation used: Hunterlab Colorflex EZ-45
Geometry: 45°/0°
Illuminant: D65
Observer: 10°
Port size: 31.8 mm

	LRV (Y ₁₀)	X ₁₀	Y ₁₀
SPC Flooring	15.49	0.4055	0.3870
Laminate Flooring (1)	33.79	0.3593	0.3619
Laminate Flooring (2)	34.96	0.3539	0.3629
Engineered Wood Flooring (1)	43.74	0.3527	0.3608
Engineered Wood Flooring (2)	28.61	0.4042	0.3915

"THIS REPORT APPLIES ONLY TO THE SAMPLES TESTED"

Samples and their identifying descriptions have been provided by the client unless otherwise stated. NZWTA Ltd makes no warranty, implied or otherwise as to the source of the tested samples. The above results are designed to provide THE CLIENT WITH GUIDANCE INFORMATION ONLY. This document shall not be reproduced except in full.


C Judan

Key Technical Person

12/07/2022



No. 1422197.2

(Please quote this number in all correspondence)

CLIENT:
Floorco Trading Ltd.
38 Galway St.
Onehunga, Auckland

Attn.: Henry Zhai

SAMPLE RECEIVED FROM:
Floorco

Date Received: 1.7.22

SAMPLE DESCRIPTION:
5 flooring planks:
a) SPC Flooring
b) Laminate Flooring (1)
c) Laminate Flooring (2)
d) Engineered Wood Flooring (1)
e) Engineered Wood Flooring (2)

Client Order No.:

Client Reference:

2 of 2



"THIS REPORT APPLIES ONLY TO THE SAMPLES TESTED"

Samples and their identifying descriptions have been provided by the client unless otherwise stated. NZWTA Ltd makes no warranty, implied or otherwise as to the source of the tested samples. The above results are designed to provide THE CLIENT WITH GUIDANCE INFORMATION ONLY. This document shall not be reproduced except in full.


C Judan

Key Technical Person

12/07/2022